

Технический паспорт продукта

Комплект проводов



Ссылочный номер

KSE 2

Комплект проводов

For the connection of the uninterruptible KNX power supply and the lead gel battery the 4-wire cable set (for one battery) must be used. For two batteries the 4-wire and the 2-wire set must be used.

The 4-wire cable set has an integrated fuse and a temperature sensor, the 2-wire cable set has only an integrated fuse.

Технические характеристики

Провод

| | |
|----------------------------|---|
| Wires: | 2-wire cable |
| Cross-section: | 0,75 мм ² |
| длина: | 2 м |
| Colour battery connection: | красный: позитивный (12 В аккумулятор) чёрный: отрицательный (GND аккумулятор) |

Терминалы

| | |
|---------------------|---|
| Battery connection: | for the connection to the uninterruptible power supply ferrules for the connection to the battery cable lug (6.3 x 0.8 mm) |
| Вид предохранения: | exchangeable fuse with in-line fuse holder (screw cap) |
| Тип предохранителя: | 5 x 20 мм, T6.3 H 250 В |

Исполнение:

дополнительный